

# Energy performance certificate (EPC)

|                                                   |                           |                     |                          |
|---------------------------------------------------|---------------------------|---------------------|--------------------------|
| 73 High Street<br>Lavenham<br>SUDBURY<br>CO10 9PT | Energy rating<br><b>D</b> | Valid until:        | 30 March 2032            |
|                                                   |                           | Certificate number: | 4732-9927-8100-0830-4276 |

|                  |                   |
|------------------|-------------------|
| Property type    | Mid-terrace house |
| Total floor area | 56 square metres  |

## Rules on letting this property


Properties can be let if they have an energy rating from A to E.

You can read [guidance for landlords on the regulations and exemptions \(https://www.gov.uk/guidance/domestic-private-rented-property-minimum-energy-efficiency-standard-landlord-guidance\)](https://www.gov.uk/guidance/domestic-private-rented-property-minimum-energy-efficiency-standard-landlord-guidance).

## Energy rating and score

This property's energy rating is D. It has the potential to be B.

[See how to improve this property's energy efficiency.](#)



The graph shows this property’s current and potential energy rating.

Properties get a rating from A (best) to G (worst) and a score. The better the rating and score, the lower your energy bills are likely to be.

For properties in England and Wales:

- the average energy rating is D
- the average energy score is 60

# Breakdown of property’s energy performance

## Features in this property

Features get a rating from very good to very poor, based on how energy efficient they are. Ratings are not based on how well features work or their condition.

Assumed ratings are based on the property’s age and type. They are used for features the assessor could not inspect.

| Feature | Description                                    | Rating    |
|---------|------------------------------------------------|-----------|
| Wall    | Solid brick, as built, no insulation (assumed) | Very poor |
| Wall    | Cavity wall, as built, no insulation (assumed) | Poor      |
| Roof    | Pitched, 250 mm loft insulation                | Good      |
| Roof    | Pitched, no insulation (assumed)               | Very poor |

| Feature              | Description                                 | Rating    |
|----------------------|---------------------------------------------|-----------|
| Window               | Single glazed                               | Very poor |
| Main heating         | Boiler and radiators, mains gas             | Good      |
| Main heating control | Programmer, room thermostat and TRVs        | Good      |
| Hot water            | From main system                            | Good      |
| Lighting             | Low energy lighting in 89% of fixed outlets | Very good |
| Floor                | Solid, no insulation (assumed)              | N/A       |
| Secondary heating    | Room heaters, wood logs                     | N/A       |

## Low and zero carbon energy sources

Low and zero carbon energy sources release very little or no CO<sub>2</sub>. Installing these sources may help reduce energy bills as well as cutting carbon emissions. The following low or zero carbon energy sources are installed in this property:

- Biomass secondary heating

## Primary energy use

The primary energy use for this property per year is 271 kilowatt hours per square metre (kWh/m<sup>2</sup>).

► [About primary energy use](#)

## How this affects your energy bills

An average household would need to spend **£615 per year on heating, hot water and lighting** in this property. These costs usually make up the majority of your energy bills.

You could **save £199 per year** if you complete the suggested steps for improving this property's energy rating.

This is **based on average costs in 2022** when this EPC was created. People living at the property may use different amounts of energy for heating, hot water and lighting.

## Heating this property

Estimated energy needed in this property is:

- 7,829 kWh per year for heating
- 1,789 kWh per year for hot water

## Impact on the environment

This property’s environmental impact rating is D. It has the potential to be A.

Properties get a rating from A (best) to G (worst) on how much carbon dioxide (CO2) they produce each year.

## Carbon emissions

|                                             |                   |
|---------------------------------------------|-------------------|
| <b>An average household produces</b>        | 6 tonnes of CO2   |
| <b>This property produces</b>               | 2.4 tonnes of CO2 |
| <b>This property’s potential production</b> | 0.4 tonnes of CO2 |

You could improve this property’s CO2 emissions by making the suggested changes. This will help to protect the environment.

These ratings are based on assumptions about average occupancy and energy use. People living at the property may use different amounts of energy.

# Steps you could take to save energy

► [Do I need to follow these steps in order?](#)

## Step 1: Flat roof or sloping ceiling insulation

|                           |               |
|---------------------------|---------------|
| Typical installation cost | £850 - £1,500 |
|---------------------------|---------------|

|                       |     |
|-----------------------|-----|
| Typical yearly saving | £54 |
|-----------------------|-----|

|                                          |      |
|------------------------------------------|------|
| Potential rating after completing step 1 | 68 D |
|------------------------------------------|------|

## Step 2: Internal wall insulation

|                           |                  |
|---------------------------|------------------|
| Typical installation cost | £4,000 - £14,000 |
|---------------------------|------------------|

|                       |     |
|-----------------------|-----|
| Typical yearly saving | £48 |
|-----------------------|-----|

|                                                 |      |
|-------------------------------------------------|------|
| Potential rating after completing steps 1 and 2 | 71 C |
|-------------------------------------------------|------|

## Step 3: Draught proofing

|                           |            |
|---------------------------|------------|
| Typical installation cost | £80 - £120 |
|---------------------------|------------|

|                       |     |
|-----------------------|-----|
| Typical yearly saving | £12 |
|-----------------------|-----|

|                                                |      |
|------------------------------------------------|------|
| Potential rating after completing steps 1 to 3 | 71 C |
|------------------------------------------------|------|

## Step 4: Solar water heating

|                           |                 |
|---------------------------|-----------------|
| Typical installation cost | £4,000 - £6,000 |
|---------------------------|-----------------|

|                       |     |
|-----------------------|-----|
| Typical yearly saving | £25 |
|-----------------------|-----|

|                                                |      |
|------------------------------------------------|------|
| Potential rating after completing steps 1 to 4 | 73 C |
|------------------------------------------------|------|

## Step 5: Double glazed windows

Replace single glazed windows with low-E double glazed windows

|                           |                 |
|---------------------------|-----------------|
| Typical installation cost | £3,300 - £6,500 |
|---------------------------|-----------------|

|                       |     |
|-----------------------|-----|
| Typical yearly saving | £61 |
|-----------------------|-----|

|                                                |
|------------------------------------------------|
| Potential rating after completing steps 1 to 5 |
|------------------------------------------------|

76 C

## Step 6: Solar photovoltaic panels, 2.5 kWp

|                           |                 |
|---------------------------|-----------------|
| Typical installation cost | £3,500 - £5,500 |
|---------------------------|-----------------|

|                       |      |
|-----------------------|------|
| Typical yearly saving | £363 |
|-----------------------|------|

|                                                |
|------------------------------------------------|
| Potential rating after completing steps 1 to 6 |
|------------------------------------------------|

90 B

## Advice on making energy saving improvements

[Get detailed recommendations and cost estimates](#)

## Help paying for energy saving improvements

You may be eligible for help with the cost of improvements:

- Free energy saving improvements: [Warm Homes Local Grant \(WHLG\)](#)
- Heat pumps and biomass boilers: [Boiler Upgrade Scheme](#)
- Help from your energy supplier: [Energy Company Obligation](#)

## Who to contact about this certificate

### Contacting the assessor

If you're unhappy about your property's energy assessment or certificate, you can complain to the assessor who created it.

|                 |              |
|-----------------|--------------|
| Assessor's name | Luke Burgess |
|-----------------|--------------|

|           |               |
|-----------|---------------|
| Telephone | 07823 772 886 |
|-----------|---------------|

---

**Email**[info@labproperty.co.uk](mailto:info@labproperty.co.uk)

---

## Contacting the accreditation scheme

If you're still unhappy after contacting the assessor, you should contact the assessor's accreditation scheme.

|                             |                                                                                    |
|-----------------------------|------------------------------------------------------------------------------------|
| <b>Accreditation scheme</b> | Elmhurst Energy Systems Ltd                                                        |
| <b>Assessor's ID</b>        | EES/024853                                                                         |
| <b>Telephone</b>            | 01455 883 250                                                                      |
| <b>Email</b>                | <a href="mailto:enquiries@elmhurstenergy.co.uk">enquiries@elmhurstenergy.co.uk</a> |

## About this assessment

|                               |                         |
|-------------------------------|-------------------------|
| <b>Assessor's declaration</b> | No related party        |
| <b>Date of assessment</b>     | 30 March 2022           |
| <b>Date of certificate</b>    | 31 March 2022           |
| <b>Type of assessment</b>     | ► <a href="#">RdSAP</a> |

## Other certificates for this property

If you are aware of previous certificates for this property and they are not listed here, please contact us at [mhclg.digital-services@communities.gov.uk](mailto:mhclg.digital-services@communities.gov.uk) or call our helpdesk on 020 3829 0748 (Monday to Friday, 9am to 5pm).

There are no related certificates for this property.



[Help \(/help\)](#) [Accessibility \(/accessibility-statement\)](#) [Cookies \(/cookies\)](#)

[Give feedback \(https://forms.office.com/e/KX25htGMX5\)](https://forms.office.com/e/KX25htGMX5)

[Service performance \(/service-performance\)](#)

## OGI

All content is available under the [Open Government Licence v3.0 \(https://www.nationalarchives.gov.uk/doc/open-government-licence/version/3/\)](#), except where otherwise stated



© Crown copyright (<https://www.nationalarchives.gov.uk/information-management/re-using-public-sector-information/uk-government-licensing-framework/crown-copyright/>)